



TOL	± mm
A	1.5
B	3.0
C	4.6
D	25.0
E	5.0

NOTE :-

- 1) ALL DIMENSIONS ARE IN m.m.
- 2) DIMENSIONS INDICATED ARE APPROXIMATE AND THE SAME ARE SUBJECT TO CHANGE DUE TO DESIGN IMPROVEMENTS WITHOUT AFFECTING THE FUNCTIONAL PARAMETERS.
- 3) STAINLESS STEEL SHEET (409) THICKNESS - 1.5 mm.
- 4) CREEPAGE DISTANCE OF CAP. BUSHING - 380 mm (MIN.)
- 5) INSULATION LEVEL - 38 / 95 KV.
- 6) COLOR SHADE - GRAY ANSI-70.
- 7) TERMINAL CONNECTORS ARE NOT IN OUR SCOPE.
- 8) * CASE SWELLING - 16 mm (MAX.)

SUPPLIER	Shreem ELECTRIC LIMITED		
OWNER	ATOMA LTD, ST. PETERBURG, RUSSIA		
CONTRACTOR	-		
PROJECT	-		
P. O. NO	14, Dt. 21-02-2024		
SIGN	DATE	450 KVAR, 10.5 KV, 3 Ø, 50 Hz, INTERNAL STAR, EXTERNAL FUSE CAPACITOR UNIT	SCALE N. T. S.
DRAWN	21/2/24		SHEET NO. 1 OF 1
CHEKD			
APPRD			REV. 0
DRG - NO - SR - CUH - A4 - 0130 - 03 - 2024			
RELEASED FOR	<input type="checkbox"/> PRELIMINARY <input type="checkbox"/> TENDER <input type="checkbox"/> INFORMATION <input checked="" type="checkbox"/> APPROVAL <input type="checkbox"/> CONSTRUCTION		