



TOL	± mm
A	1.5
B	3.0
C	4.6
D	25.0
E	5.0

NOTE :-

- 1) ALL DIMENSIONS ARE IN m.m.
- 2) DIMENSIONS INDICATED ARE APPROXIMATE AND THE SAME ARE SUBJECT TO CHANGE DUE TO DESIGN IMPROVEMENTS WITHOUT AFFECTING THE FUNCTIONAL PARAMETERS.
- 3) STAINLESS STEEL SHEET (409) THICKNESS - 1.5 mm.
- 4) CREEPAGE DISTANCE OF CAP. BUSHING - 380 mm (MIN.)
- 5) INSULATION LEVEL - 38 / 95 KV.
- 6) COLOR SHADE - GRAY ANSI-70.
- 7) TERMINAL CONNECTORS ARE NOT IN OUR SCOPE.
- 8) * CASE SWELLING - 12 mm (MAX.)

SUPPLIER	Shreem ELECTRIC LIMITED		
OWNER	ATOMA LTD, ST. PETERBURG, RUSSIA		
CONTRACTOR	-		
PROJECT	-		
P. O. NO	14, DL 21-02-2024		
	SIGN	DATE	
DRAWN	<i>[Signature]</i>	<i>12/2/24</i>	150 KVAR, 10.5 KV, 3 Ø, 50 Hz, INTERNAL STAR, EXTERNAL FUSE CAPACITOR UNIT
CHEKD	<i>[Signature]</i>	<i>12/2/24</i>	
APPRD	<i>[Signature]</i>	<i>12/2/24</i>	
DRG - NO - SR - CUH - A4 - 0128 - 03 - 2024			SCALE N. T. S.
			SHEET NO. 1 OF 1
			REV. 0
RELEASED FOR	<input type="checkbox"/> PRELIMINARY <input type="checkbox"/> TENDER <input type="checkbox"/> INFORMATION <input checked="" type="checkbox"/> APPROVAL <input type="checkbox"/> CONSTRUCTION		